


2nd Floor		
T5 2x28W/840	0	0
18W/825 E27	2	36
35W/830 G12	3	105



No.	Floor	Room type	Area (m2)	Luminarie Type	Number of lamps	Power (W)	Total power (W)	Luminous flux (lm)	Total Luminous flux (lm)	Maintained illuminance (lx)	Standard illuminance (lx)	Light color	Min Total Luminous Flux (lm)
14	2 nd Floor	Toilet	4,64	18W/825 E27	1	18	18	1160	1160	250	200	825	928
15	2 nd Floor	Stairs	7,85	35W/830 G12	1	35	35	3600	3600	459	150	830	1177,5
16	2 nd Floor	Corridor	4,18	18W/825 E27	1	18	18	1160	1160	278	100	825	418
17	2 nd Floor	Corridor	11,95	35W/830 G12	1	35	35	3600	3600	301	100	830	1195
18	2 nd Floor	Corridor	22,46	35W/830 G12	1	35	35	3600	3600	160	100	830	2246

DELTER
Support to Meet Requirements of the Energy Community Treaty for SEE Focusing on Energy Efficiency and Renewables

PROJECT: Municipality of Trebinje administration building
CADCODE: TRB-PLOTDRW-03
SCALE:
DATE: 10.10.2011