


1st Floor		
	pcs.	Power (W)
T5 2x28W/840	58	1624
18W/825 E27	12	216
35W/830 G12	5	175



No.	Floor	Room type	Area (m2)	Luminarie Type	Number of lamps	Power (W)	Total power (W)	Luminous flux (lm)	Total Luminous flux (lm)	Maintained illuminance (lx)	Standard illuminance (lx)	Light color	Min Total Luminous Flux (lm)
49	1 st Floor	Classroom	55,80	T5 2x28W/840	8	28	224	2600	20800	373	300	840	16740
50	1 st Floor	Classroom	37,82	T5 2x28W/840	6	28	168	2600	15600	412	300	840	11346
51	1 st Floor	Corridor	81,80	35W/830 G12	4	35	140	3600	14400	176	100	830	8180
52	1 st Floor	Classroom	18,00	T5 2x28W/840	4	28	112	2600	10400	578	300	840	5400
53	1 st Floor	Assembly	37,80	T5 2x28W/840	8	28	224	2600	20800	550	500	840	18900
54	1 st Floor	Kitchen	7,00	T5 2x28W/840	2	28	56	2600	5200	743	500	840	3500
55	1 st Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
56	1 st Floor	Kitchen	6,00	T5 2x28W/840	2	28	56	2600	5200	867	500	840	3000
57	1 st Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
58	1 st Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
59	1 st Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
60	1 st Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
61	1 st Floor	Stairs	17,20	35W/830 G12	1	35	35	3600	3600	209	150	830	2580
62	1 st Floor	Corridor	7,60	18W/825 E27	1	18	18	1160	1160	153	100	825	760
64	1 st Floor	Office	11,52	T5 2x28W/840	4	28	112	2600	10400	903	500	840	5760
65	1 st Floor	Office	19,80	T5 2x28W/840	4	28	112	2600	10400	525	500	840	9900
66	1 st Floor	Office	19,80	T5 2x28W/840	4	28	112	2600	10400	525	500	840	9900
67	1 st Floor	Classroom	55,80	T5 2x28W/840	8	28	224	2600	20800	373	300	840	16740
68	1 st Floor	Storage	20,30	18W/825 E27	2	18	36	1160	2320	114	100	825	2030
69	1 st Floor	Classroom	55,80	T5 2x28W/840	8	28	224	2600	20800	373	300	840	16740
70	1 st Floor	Toilet	2,50	18W/825 E27	1	18	18	1160	1160	464	200	825	500
71	1 st Floor	Toilet	2,50	18W/825 E27	1	18	18	1160	1160	464	200	825	500
72	1 st Floor	Toilet	2,50	18W/825 E27	1	18	18	1160	1160	464	200	825	500
73	1 st Floor	Toilet	2,50	18W/825 E27	1	18	18	1160	1160	464	200	825	500

DELTER
Support to Meet Requirements of the Energy Community Treaty for SEE Focusing on Energy Efficiency and Renewables

PROJECT: Elementary School "Sveti Sava" Zvornik
CADCODE: ZVR-PLOTDRW-02
SCALE:
DATE: 10.10.2011



A project implemented by EPTISA in Consortium with MVV and Kantor

