


1st Floor		
	pcs.	Power (W)
T5 2x28W/840	18	504
18W/825 E27	4	72
35W/830 G12	4	140



No.	Floor	Room type	Area (m2)	Luminarie Type	Number of lamps	Power (W)	Total power (W)	Luminous flux (lm)	Total Luminous flux (lm)	Maintained illuminance (lx)	Standard illuminance (lx)	Light color	Min Total Luminous Flux (lm)
3	1 <sup>st</sup> Floor	Corridor	12,82	35W/830 G12	1	35	35	3600	3600	281	100	830	1282
4	1 <sup>st</sup> Floor	Corridor	21,34	35W/830 G12	1	35	35	3600	3600	169	100	830	2134
5	1 <sup>st</sup> Floor	Office	13,79	T5 2x28W/840	4	28	112	2600	10400	754	500	840	6895
6	1 <sup>st</sup> Floor	Office	12,88	T5 2x28W/840	4	28	112	2600	10400	807	500	840	6440
7	1 <sup>st</sup> Floor	Office	25,63	T5 2x28W/840	6	28	168	2600	15600	609	500	840	12815
8	1 <sup>st</sup> Floor	Office	15,69	T5 2x28W/840	4	28	112	2600	10400	663	500	840	7845
9	1 <sup>st</sup> Floor	Corridor	3,05	18W/825 E27	1	18	18	1160	1160	380	100	825	305
10	1 <sup>st</sup> Floor	Toilet	7,56	18W/825 E27	2	18	36	1160	2320	307	200	825	1512
11	1 <sup>st</sup> Floor	Corridor	24,32	35W/830 G12	1	35	35	3600	3600	148	100	830	2432
12	1 <sup>st</sup> Floor	Corridor	2,95	18W/825 E27	1	18	18	1160	1160	393	100	825	295
13	1 <sup>st</sup> Floor	Kitchen	6,84	35W/830 G12	1	35	35	3600	3600	526	500	830	3420

## DELTER

Support to Meet Requirements of the Energy Community Treaty for SEE Focusing on Energy Efficiency and Renewables

PROJECT:	Municipality of Trebinje administration building
CADCODE:	TRB-PLOTDRW-02
SCALE:	
DATE:	10.10.2011