


2nd Floor

	pcs.	Power (W)
T5 2x28W/840	52	1456
18W/825 E27	9	162
35W/830 G12	4	140



No.	Floor	Room type	Area (m2)	Luminaire Type	Number of lamps	Power (W)	Total power (W)	Luminous flux (lm)	Total Luminous flux (lm)	Maintained illuminance (lx)	Standard illuminance (lx)	Light color	Min Total Luminous Flux (lm)
74	2 nd Floor	Classroom	55,80	T5 2x28W/840	8	28	224	2600	20800	373	300	840	16740
75	2 nd Floor	Classroom	37,80	T5 2x28W/840	6	28	168	2600	15600	413	300	840	11340
76	2 nd Floor	Corridor	99,00	35W/830 G12	4	35	140	3600	14400	145	100	830	9900
77	2 nd Floor	Classroom	55,80	T5 2x28W/840	8	28	224	2600	20800	373	300	840	16740
78	2 nd Floor	Classroom	55,80	T5 2x28W/840	8	28	224	2600	20800	373	300	840	16740
79	2 nd Floor	Classroom	55,80	T5 2x28W/840	8	28	224	2600	20800	373	300	840	16740
80	2 nd Floor	Office	20,30	T5 2x28W/840	4	28	112	2600	10400	512	500	840	10150
81	2 nd Floor	Classroom	55,80	T5 2x28W/840	8	28	224	2600	20800	373	300	840	16740
82	2 nd Floor	Office	10,80	T5 2x28W/840	2	28	56	2600	5200	481	500	840	5400
83	2 nd Floor	Toilet	8,00	18W/825 E27	2	18	36	1160	2320	290	200	825	1600
84	2 nd Floor	Toilet	5,00	18W/825 E27	1	18	18	1160	1160	232	200	825	1000
85	2 nd Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
86	2 nd Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
87	2 nd Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
88	2 nd Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
89	2 nd Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
90	2 nd Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400

DELTER

Support to Meet Requirements of the Energy Community Treaty for SEE Focusing on Energy Efficiency and Renewables

PROJECT:

Elementary School "Sveti Sava" Zvornik

CADCODE:

ZVR-PLOTDRW-03

SCALE:

DATE:

10.10.2011