



EUROPEAN UNION

Delegation of the European Union to Bosnia and Herzegovina

Clarification No. 1

Project Title: **Supply of equipment for a Modular Power supply of SDH telecommunication nodes**

Publication reference: **EuropeAid/132-652/L/SUP/BA**

Tender No: **EC/BiH/TEN/11/032**

Question 1: Referring Technical specification item 1.2 and item 1.8: Can we offer a better method for battery testing e.g. "battery asymmetry test" instead of "battery capacity test"? This method is the only one that gives the most exact results regarding the battery conditions.

Answer 1: Yes.

Question 2: We have question about the part which refer to the 48 VDC battery (pages 7 & 16 of Annex II + III Technical Specifications + Technical Offer): Capacity of 300Ah refers to the capacity of whole battery string or is it capacity for one battery?

Answer 2: Capacity of 300Ah refers to the capacity of whole battery string (pages 7 and 16 of Annex II + III Technical Specifications + Technical Offer)